CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION OFFICE OF THE STATE FIRE MARSHAL

FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. Page 1 of 1 7165-0900:130

CATEGORY: Control Unit (Non High-Rise)

LISTEE: Fike Protection Systems, 704 S. 10th St., Blue Springs MO 64015

Contact: Kevin Montgomery (816) 229-3405 FAX (816) 229-0314

DESIGN: Model GP-5 control unit. Local and central station, noncoded, automatic, manual,

waterflow and sprinkler supervisory service. Refer to listee's data sheet for detailed

product description and operational considerations. System components:

GP-5 Control Unit ADM-24/GP-5RA Driver/Annunciator CAC-5F

Initiating Converter Indicating Converter NACA-2F DP-5024 **Dead Font Panel** Battery (Supervised) Lead Acid Only

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances

and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model designation, electrical rating, and UL label.

APPROVAL: Listed as a fire alarm control unit for use with separately listed compatible initiating and

indicating devices.

This control unit can generate the temporal code pattern fire alarm signal as required per

NFPA 72, 1999 Edition. Refer to manufacturer's Installation Manual for details.

NOTE: For alarm verification feature, the retard/reset/restart must be adjusted to 30 seconds or

less.

XLF: 7165-0075:175

01-23-04



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

JANUARY 23, 2004 Date Issued: Listing Expires June 30, 2004

DIANE K. AREND, Senior Deputy Authorized By:

Program Manager